



# Certificate of Compliance

Certificate: 2598257

Master Contract: 257746

Project: 2624691

Date Issued: May 10, 2013

Issued to: **Paramount Industries**  
**#70, 5th Cross SSI Area, Rajajinagar,**  
**Karnataka, Bangalore - 560010**  
**INDIA**  
Attention: **Mr. Akash Ranka**

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only*



Issued by: *Sham Das Gupta*  
Shaon Das Gupta

## PRODUCTS

CLASS 3211-04 INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers – Magnetic  
CLASS 3211-84 INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Magnetic  
- Certified to US Standards

Industrial Control Relays P1, P2 and P3 Series:

Contact Rating:

Model P1 series	10A Resistive, 250 VAC, 50/60HZ 10A Resistive, 30 VDC
Model P2 series	7A Resistive, 250 VAC, 50/60HZ, 7A Resistive, 30 VDC
Model P3 Series	10A Resistive, 240 VAC, 50/60HZ, 10A Resistive 30 VDC

Coil Voltage:



**Certificate:** 2598257

**Master Contract:** 257746

**Project:** 2624691

**Date Issued:** May 10, 2013

P1 & P2 series	
AC Coil	12V, 24V, 48V, 115V, 230V AC,50/60Hz
DC Coil	12V, 24V, 48V, 110V DC
P3 series	
AC coil	12V, 24V, 48V, 110V, 230V AC.50/60Hz
DC coil	12V, 24V, 48V, 110V, 220 DC

P1 may be followed by A, may be followed by T, may be followed by B\*, F, I, P, R#, Z or any combination of those letters, may be followed by 1 or 2, followed by 12VAC, 12VDC, 24VAC, 24VDC, 48VAC, 48VDC, 110VDC, 115VAC or 230 VAC.

P2 may be followed by A, may be followed by B\*, F, I, P, R#, Z or any combination of those letters, may be followed by 1 or 2, followed by 12VAC, 12VDC, 24VAC, 24VDC, 48VAC, 48VDC, 110VDC, 115VAC or 230 VAC.

P3 may be followed by 2 or 2A or 3 or X or Y or 3A, may be followed by T, may be followed by B\*, F, I, P, R#, Z or any combination of those letters, may be followed by 1 or 2, followed by 12VAC, 12VDC, 24VAC, 24VDC, 48VAC, 48VDC, 110VDC, 110VAC, 220VDC or 230 VAC.

Note:

\*- This feature Cover voltage upto 48Vac/dc

#- this feature Cover voltage only 115Vac, 230Vac

Conditions of Acceptability -

1. These are open type relays which are certified as components for use only in other certified equipment where the suitability of the combination is to be determined by the CSA International.

2. These devices are for factory wiring only.

3. These relays have been evaluated for a maximum surrounding air temperature rating of 0 to 70C for DC & 0 to +55C for AC

### **APPLICABLE REQUIREMENTS**

CSA C22.2 NO 14-10  
UL Std No 508(17<sup>th</sup> Ed.)

- Industrial Control Equipment
- Industrial Control Equipment



## *Supplement to Certificate of Compliance*

**Certificate:** 2598257

**Master Contract:** 257746

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
2624691	May 10, 2013	Update of Report 2598257 to correct for typographical error.
2598257	February 19, 2013	Original Certification.