



ELECTRONICS TEST AND DEVELOPMENT CENTRE

(STQC Directorate, Ministry of Communications & Information Technology)
100 ft Road, Peenya Industrial Estate, Bangalore-560 058
(Tel: 2839 5992, 2839 4647. Fax: 080 - 2839 1804)
E-mail: mailetcd29@yahoo.com

Report No.: TR/EMC/61900-2

TEST REPORT

Page 01 of 02

1. Scope

1.	Service request number	61900
2.	Requested by (Name & Address of the Organization)	M/s.Paramount Industries No.70,S.S.I.Area,5 th Cross, Rajajinagar,Banaglore 560010
3.	Description of the equipment:	
	a) Nomenclature	Electromagnetic Relay
	b) Manufactured by	Paramount Industries
	c) Model / type no.	P2-A-FW-M
	d) Serial no.	002
4.	Date of submission of test samples	05-10-2012
5.	Condition of test samples on receipt	Good
6.	Date of start of tests	05-10-2012
7.	Date of completion of tests	05-10-2012
8.	Applicable test specification	As per customer specification
9.	Test category	Performance test
10.	Environment condition	Temp: 25±5 °C RH: 40 to 75%

2. Major equipments used

SN	Nomenclature	Make	Model	Cal. Due
1	Voltage surge simulator	EM Test	VSS 500-M	29-06-2013

This report refers only to the item tested and shall not be reproduced except in full. Refer to information contained on the cover.

FM/081-10

Date of Release: 30/06/2010





ELECTRONICS TEST AND DEVELOPMENT CENTRE

(STQC Directorate, Ministry of Communications & Information Technology)
100 ft Road, Peenya Industrial Estate, Bangalore-560 058
(Tel: 2839 5992, 2839 4647. Fax: 080 - 2839 1804)
E-mail: mailetcdc29@yahoo.com

Report No.: TR/EMC/61900-2

Page 02 of 02

Results:


Test Parameter : Impulse


Test Specification : As per customer specification


Test Procedure : IEC 60255-5

EUT Configuration : Electromagnetic Relay having 2 change over contacts 1-2(NO), 7-8(NO) & with A1 (4) & A2 (5) Terminals for coil voltage of 24V DC.

Wave shape / severity	Requirements	Test results
Rise Time : 1.2 μ Sec Pulse width : 50 μ Sec Test Voltage : 5 kV Polarity : +ve & -ve. No. of pulses : 3 in each polarity Interval of pulses : 5 sec Point of application : i) Contact Between 1&2. ii) Contact Between 7&8. iii) Between all contacts shorted to body. iv) Between 1&2 short to 7&8 shorted.	Performance criteria -No flash over / Disruptive discharge/ Puncture shall occur during the test. -Before and after the test relay should work satisfactorily.	-No flash over /Disruptive discharge /Puncture observed during the test. -Before and after the test relay was working satisfactorily.

Tested By 
(Hemant Kumar Sahu)
(Scientist 'B')

Approved By 
Dr. N.C. JOSHI
Scientist 'E'
Electronics Test & Development Centre
Ministry of Comm. & IT., STQC Directorate,
Govt. of India, Bangalore - 560 058.

Issued By 
CO-ORDINATOR
TESTING SERVICES,
E.T.D.C., BANGALORE

